

## **2-02/025.00 - Security Alarms**

All security alarms and panic alarms in lockup areas shall be tested daily by the assigned personnel. Any malfunctions will be noted in the Uniform Daily Activity (UDAL)/Title 15 Log and the Branch Supervisor will be notified.

---