

## 3-06-040 Location and Inspection of Air Packs and Fire Extinguishers

## 3-06-040 Location and Inspection of Air Packs and Fire Extinguishers

**Effective Date:** 02-09-92

**Revision Date:** 5-11-17

**Review Date:** 5-11-19

**Reference:** CDM 3-14/070.00, 3-14/080.00, and 4-11/020.00

### **PURPOSE OF ORDER:**

The purpose of this order is to establish guidelines for the placement, maintenance and inspection of air packs and fire extinguishers at Pitchess Detention Center (PDC) South Facility.

### **SCOPE OF ORDER:**

This order applies to all personnel assigned to, and working at South Facility.

### **ORDER:**

Fire response gear is located throughout South Facility in compliance with all State and Federal regulations. This equipment shall be inspected and logged, on a daily basis, in the Unit **Uniform** Daily Activity Log (UDAL) or electronic Uniform Daily Activity Log (e-UDAL).

### AIR PACK & TURNOUT GEAR LOCATIONS

Air packs and turnout gear are located at the following locations within the facility:

- Administration Building - Two (2) self-contained breathing apparatus (SCBA) packs and two sets of turnout gear mounted in the ~~Fire Gear room~~ **closet labeled "Fire Gear,"** located inside of security, in the main administration hallway, near the sally port. Two (2) SCBA packs located in the armory, with five (5) spare bottles.
- Visiting - Two (2) SCBA packs and two (2) sets of turnout gear located in the cabinet, inside security, in the officers' work area.
- Eddie Compound Briefing Room - Two (2) SCBA packs and two (2) sets of turnout gear located in the locked ~~"Fire Gear"~~ cabinet **labeled "Fire Gear"**.

Pitchess Detention Center - South Facility : 3-06-040 Location and Inspection of Air  
Packs and Fire Extinguishers

---

AIR PACK AND TURNOUT GEAR DAILY INSPECTIONS

All SCBA and turnout gear at South Facility shall be inspected on a daily basis and logged in the appropriate UDAL book or e-UDAL. A separate "Inspection and Maintenance Check List" will **shall** be kept with the fire gear and shall be signed by the inspecting officer. The following compounds shall be responsible for the daily inspections of the specified equipment:

- Adam Compound - Adam compound personnel shall be responsible for inspecting and logging all fire gear located in the administration building, listed above.
- Eddie Compound - Eddie compound personnel shall be responsible for inspecting and logging all fire gear located in the Eddie compound briefing room, listed above.
- Henry Compound - Henry compound personnel shall be responsible for inspecting and logging all fire gear located in the visiting center, listed above.

FIRE EXTINGUISHERS & HOSES

Fire extinguishers and hoses are located throughout South Facility. All fire extinguishers and hoses shall be maintained and inspected on a monthly basis by the Facility maintenance coordinator utilizing the fire equipment inspection checklist (see Appendix 73-13-040).

Every December, the South Facility maintenance officer shall make a request through Facilities Services Bureau (FSB) to service and re-charge all of South Facility's fire extinguishers. Fire hoses are required to be replaced every five years.

Fire extinguisher and hose locations are as follows:

ADMINISTRATION BUILDING (INSIDE SECURITY)

- One mounted on the wall in the secretary's office next to the copy machine
- One fire extinguisher and a 75' fire hose located in the main hallway outside of the watch commander's office
- One fire extinguisher mounted on the wall inside the main hallway briefing room
- One fire extinguisher mounted on the wall inside of the maintenance office
- One fire extinguisher mounted on the inside of the clinic
- One fire extinguisher mounted on the wall inside the dental office
- One fire extinguisher mounted on the wall inside the medical secretary's office.
- One fire extinguisher mounted on the wall inside the infirmary medication room.

ADMINISTRATION BUILDING (OUTSIDE SECURITY)

- One fire extinguisher mounted on the wall in the hallway next to the outer security door
- One fire extinguisher and fire hose located in the hallway outside room #172
- One fire extinguisher mounted on the wall outside the captain's office

INMATE DINING ROOM (IDR)

Pitchess Detention Center - South Facility : 3-06-040 Location and Inspection of Air  
Packs and Fire Extinguishers

---

- One fire extinguisher mounted on the wall inside the rear store room in the IDR
- One 50' fire hose located on the south wall of the IDR
- One fire extinguisher located in the kitchen office
- One fire extinguisher located on the east wall of the kitchen
- One 50' fire hose located outside the kitchen office

BARRACKS 30 - 39 (UPPER COMPOUND)

- Each barrack has a fire hose located inside at the rear of the barrack. Barrack 30 has a 100' hose section, while barracks 31-39 have 75' hoses

BARRACKS 41, 43, 45, 47, 49, 51 (LOWER COMPOUND)

- Each barrack listed above has a fire extinguisher located outside the front door, which meets the minimum Fire Department requirement

OTHER

- Two fire extinguishers located inside the school
- One fire extinguisher located in the library
- One fire extinguisher located in the barber shop
- One fire extinguisher located in the church
- One fire extinguisher located in the officer station at the South visiting area

**Revision Date 10/30/20**

**09/10/97 SOUF**

---